

This is to Certify

TELEDATA S.r.I.

Via Giulietti 8, Milan, 20132, Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

SF1000 Analogue addressable photoelectric smoke detector

which has complied with the requirements of the following:

EN 54-7: 2000 + A1: 2002 + A2: 2006

EN 54-17: 2005

Certificate No: 928b-(cl-6)

Issue Number: 01

Date of Issue: 22 July 2010

Signed for and on behalf of LPCB





M McCULLAGH

breglobal

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.



Appendix to Certificate

Certificate No: 928b-(cl-6)

TELEDATA S.r.I.

Certificated Products

LPCB Ref. No.

SF1000

Analogue addressable photoelectric smoke detector with short circuit isolator 928b/01

(BS100, BS100E, BS100/S and BS100E/S bases)

Note:

1. Meets the requirements of EN 54-7 at the following sensitivity settings:

Optical only level 1 - High Optical only level 2 Optical only level 3

Optical only level 4 - Low

Bases

BS100 Universal adaptor base BS100E Vega adaptor base

BS100/S Universal adaptor base with shorting clip BS100E/S Vega adaptor base with shorting clip

Appendix Issue No: 01

Page: 2 of 2

Date of Issue: 22 July 2010

Signed for and on behalf of LPCB





M McCULLAGH

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.