

## Certificate of Product Approval

Certificate Number: 1154c-(cl-1)

Issue: 01

### Teledata S.r.l

Via Giulietti 8  
Milan  
20132  
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Heat & Smoke Detectors**  
SF5200

#### Standards

**EN 54-5:2000 + A1:2002**  
**EN 54-7:2000 + A1:2002 + A2:2006**  
**EN 54-17:2005**  
**CEA 4021: 2003**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Martin McCullagh  
Verifier

28 October 2016  
Date of Issue

28 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 1154c-(cl-1) Teledata S.r.l

Issue: 01

Certified Product	Description	LPCB Ref.No.
SF5200	<p>Analogue Addressable Class P Heat and Photoelectric Smoke Multi-sensor Detector with Short Circuit Isolator (BS5000 base)</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>Meets the requirements of EN 54-5 for (Class A1) &amp; EN 54-7 at the following settings: Multi Criteria Level 1 (most sensitive) – Thermally enhanced smoke detection with class A1 heat response Multi Criteria Level 2 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria Level 3 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria level 4 (least sensitive) – Thermally enhanced smoke detection with Class A1 heat response</li> <li>Meets the requirements of EN 54-5 (class A1R) at the following settings: Class A1R heat only response</li> <li>Meets the requirements of EN 54-7 at the following settings: Optical only level 1 – High Optical only level 2 Optical only level 3 Optical only level 4 - Low</li> </ol>	1154c/02

### Bases

BS5000      Adaptor base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh  
Verifier

28 October 2016  
Date of Issue

28 October 2016  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)


