

Certificate of Product Approval

Certificate Number: 1154f-(cl-1)

Issue: 01

Teledata S.r.l

Via Giulietti 8
Milan
20132
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Criteria Detectors
SF5200E

Standards

EN 54-5:2000 + A1:2002
EN 54-7:2000 + A1:2002 + A2:2006
CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Martin McCullagh
Verifier

28 October 2016
Date of Issue

28 October 2016
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1154f-(cl-1) Teledata S.r.l

Issue: 01

Certified Product	Description	LPCB Ref.No.
SF5200E	<p>Analogue Addressable Class P Heat and Photoelectric Smoke Multi-Sensor Detector Lite (BS5000 base)</p> <p>Notes:</p> <ol style="list-style-type: none"> Meets the requirements of EN 54-5 (Class A1) & EN 54-7 at the following settings: <ul style="list-style-type: none"> Multi Criteria level 1 (most sensitive) – Thermally enhanced smoke detection with Class A1 Heat Response Multi Criteria Level 2 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria Level 3 – Thermally enhanced smoke detection with Class A1 heat response Multi Criteria level 4 (least sensitive) – Thermally enhanced smoke detection with Class A1 heat response Meets the requirements of EN 54-5 (Class A1R) at the following settings: Class A1R heat only response Meets the requirements of EN 54-7 at the following settings: <ul style="list-style-type: none"> Optical only level 1 – High Optical only level 2 Optical only level 3 Optical only level 4 - Low 	1154f/02

Bases

BS5000 Adaptor base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Martin McCullagh
Verifier

28 October 2016
Date of Issue

28 October 2016
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


