



Head Office:

Via Brescia 24 G
20063 Cernusco sul Naviglio (MI)
Tel. + 39 02.27.20.13.52
E-mail: info@teledata-i.com

www.teledata-i.com

EC - Declaration of performance

N.5/2017

According to Regulation EU No. 305/2011

1- Code of the product / type: **TELEDATA ONE.**

2- Type number: **TELEDATA ONE.**

Description: **Addressable Fire Alarm Control Panel**

3- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings

4- Manufacturer: **Teledata s.r.l.**,
operational headquarters : **Via Brescia, 24/G Cernusco S/N - 20063 Milano**
registered office : **Via Giulietti, 8, 20132 Milano, Italy**

5- Trading Company: **Teledata s.r.l.**,
operational headquarters : **Via Brescia, 24/G Cernusco S/N - 20063 Milano**
registered office : **Via Giulietti, 8, 20132 Milano, Italy**

6- System of assessment: **System 1**

7- Notify Body: **EVPU a.s., 19 Trencianska Str., 018 51 Nova Dubnica, Slovakia**

Notify Body Number: **1293**

EC Certificate n°: **1293 – CPR – 0411 rev.2**





8- Declared Performance:

Essential characteristics	Performance	Harmonized technical spec. EN 54/2:1997/A1:2006/AC1999	Harmonized technical spec. EN 54/4:1997/A2:2006:2006/AC:1999
Performance under fire conditions	PASS	cl. 4,5,7	-
Response delay (response time to fire)	PASS	cl. 7.1, 7.7	-
Operational reliability	PASS	cl.4 to 10, 12,13,14	cl. 4, 5, 6, 7, 8
Performance of power supply	PASS	-	cl. 4, 5, 6
Durability of operational reliability and response delay -temperature resistance	PASS	cl. 15.4	cl. 9.5
Durability of operational reliability and response delay -vibration resistance	PASS	cl. 15.6, 15.7, 15.15	cl. 9.7, 9.8, 9.15
Durability of operational reliability and response delay -electrical stability	PASS	cl. 15.8, 15.13	cl. 9.9
Durability of operational reliability and response delay -humidity resistance	PASS	cl. 15.5, 15.14	cl. 9.6, 9.14

9- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4:

Your Faithfully.

June 12th , 2017

Luca SEBASTIO
Quality Manager

