

# BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

**2831-CPR-F0217**

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

### SG200 Wireless Multi-Criteria Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Argus Security Srl**  
**Via del Canneto**  
**14- Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

**Argus Security Srl**  
**Via del Canneto**  
**14- Valle delle Noghere**  
**34015 Muggia**  
**Trieste**  
**Italy**

Choose an item or hit spacebar.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-5:2000 + A1:2002 – Heat Detectors – Point Detectors**

**EN 54-7:2000 + A1:2002 + A2:2006 – Smoke Detectors – Point Detectors using Scattered Light, Transmitted Light or Ionisation**

**EN 54-25:2008 – Components using Radio Links**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 17 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P. Halligan, Certification Engineer

Date of First Issue: 17 October 2019

Date of Issue: 17 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland**

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0217**

**SG200 Wireless Multi-Criteria Detector**

**Notes:**

1. Meets the requirements of EN 54-5 for Class A1R
2. Meets the requirements of EN 54-7 in the normal sensitivity setting
3. The device must be used with the following batteries only
  - CR123A (3 Vdc) – Main Battery
  - CR2032A (3 Vdc) – Secondary Battery

**Bases:**

WAB100 – Wireless Adapter Base

*P. Halligan*

P. Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 17 October 2019

Date of issue: 17 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)